

Classification

Number	24-003056-PR04 (NW-H01-09-en-01)
Owner	Pellini S.p.A. Via Fusari, 19 26845 Codogno-Lo Italy
Product	Insulating glass units with integrated slatted blinds in the cavity
Designation	System: SL27MB
Details	Overall dimensions (W x H) 1500 mm x 3000 mm; Glass configuration TSG 8 mm / Spacer 27 mm / TSG 8 mm; Coating Sunguard SN 70/35; Coating level 2; Spacer: Material polyvinyl chloride (PVC); Designation SL27MB; Slats: Material: aluminium, 16 mm x 0.20 mm; Colour: S157; Pull cords: Material polyester; Item No. SL1165; Ladder cord: Material polyester; Item No.: SL1253; Drive unit: Motor Interna brushless motor; End stop Mechanical and electronic end stop
Special features	-/-

Result **)



The requirements of ift-Guideline VE07/3, section 6.2, for durability (20 000 cycles) are fulfilled.


**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

Basis

ift-Guideline VE-07/3:2018-11

Test report: 24-003056-PR04 PB-H01-09-de-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-qeprueft
ID: 932-D9FCA

ift Rosenheim

11.12.2025



Michael Freinberger, Dipl.-Ing. (FH)
Head of Testing Department
Material Testing

Stefan Hehn, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing