

Classification

Number	24-003056-PR02 (NW-H01-09-en-02)
Owner	Pellini S.p.A. Via Fusari, 19 26845 Codogno-Lo Italy
Product	Insulating glass units with integrated slatted blinds in the cavity
Designation	System: SL27MB
Details	Overall dimensions (W x H) 3000 mm x 1500 mm; Glass configuration TSG 8 mm / Spacer 27 mm / TSG 8 mm; Spacer: Material polyvinyl chloride (PVC); Designation SL27MB; Slats: Material: aluminium, 16 mm x 0.20 mm; Colour: S157; Pull cords: Material polyester; Item No. SL1165; Ladder cord: Material polyester; Item No.: SL1253; Drive unit: Motor Interna brushless motor; End stop Mechanical and electronic end stop
Special features	-/-

Result



The requirements of ift-Guideline VE07/3, section 6.1, for durability (20 000 cycles) are fulfilled.

Basis *)

ift-Guideline VE-07/3:2018-11

*) and corresponding national versions (e.g. DIN EN)

Test report: 24-003056-PR02 PB-H01-09-de-02

Replaces ift-Nachweis:

24-003056-PR02 NW-H01-09-en-01 dated 31.07.2025

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-qeprueft
ID: CE9-75E22

ift Rosenheim

26.09.2025



Michael Freinberger, Dipl.-Ing. (FH)
Head of Testing Department
Material Testing

Stefan Hehn, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing